

NOTES

- A.** NO WORK SHALL BE APPROVED OR ACCEPTED BY THE CITY UNLESS 2 WORKING DAYS NOTICE OF COMMENCING WORK IS GIVEN TO THE CITY.
- B.** ALL TEMPORARY PAVEMENT AND SIDEWALK SHALL BE MAINTAINED BY THE CONTRACTOR OR THE DEVELOPER AT HIS OWN EXPENSE IN A SUITABLE AND SAFE CONDITION FOR TRAFFIC UNTIL PERMANENT REPLACEMENT IS MADE OR THE PROJECT IS FINALLY ACCEPTED BY THE CITY.
- C.** ALL STORM SEWER CONSTRUCTION SHALL ADHERE TO ODOT SPECIFICATIONS LATEST REVISION OR WITH THE CITY STORM SEWER SPECIFICATIONS, WHICHEVER IS APPLICABLE AND MORE RESTRICTIVE.
- D.** MASTIC MATERIAL IS REQUIRED ON ALL NON O-RING STORM SEWER AND MANHOLES, UNLESS OTHERWISE APPROVED.
- E.** WHEN A CASTING IS REMOVED IT REMAINS CITY PROPERTY AND TO BE DELIVERED TO THE CITY SERVICE CENTER, UNLESS OTHERWISE APPROVED.
- F.** ANY DETAILS OR NOTES NOT DIRECTLY ADDRESSED IN THESE ENGINEERING STANDARDS SHALL BE COORDINATED WITH THE CITY ENGINEERING DEPARTMENT.
- G.** ALL STORM SEWER SHALL BE INSTALLED USING A PIPE LASER, INSIDE THE PIPE IF POSSIBLE, FOR GRADE AND ALIGNMENT.

UTILITY STAKING

- A.** OFFSET AND GRADE AT EACH MANHOLE, CATCH BASIN, AND OTHER STRUCTURES. OFFSET AND GRADE 50' AND 100' OUT FROM EACH MANHOLE UNLESS OTHERWISE APPROVED.

PIPE

- A.** ALL STORM SEWER PIPE SHALL HAVE A MINIMUM DIAMETER OF 12", UNLESS OTHERWISE APPROVED.

- B.** TYPES OF PIPE PERMITTED

OUTSIDE THE RIGHT-OF-WAY AND UP TO 30" DIAMETER

ODOT MATERIALS NUMBER

- REINFORCED CONCRETE PIPE
- REINFORCED CONCRETE ELLIPTICAL PIPE
- CORRUGATED POLYETHYLENE SMOOTH-LINED PIPE
- POLYVINYL CHLORIDE PLASTIC PIPE (NON-PERFORATED)
- POLYVINYL CHLORIDE CORRUGATED SMOOTH-INTERIOR PIPE
- POLYVINYL CHLORIDE PROFILE WALL PIPE
- POLYVINYL CHLORIDE SOLID WALL PIPE

- 706.02
- 706.04
- 707.33
- 707.41
- 707.42
- 707.43
- 707.45

WITHIN THE RIGHT-OF-WAY OR OVER 30" DIAMETER

ODOT MATERIALS NUMBER

- REINFORCED CONCRETE PIPE
- REINFORCED CONCRETE ELLIPTICAL PIPE

- 706.02
- 706.04

EXISTING TILE HOOKUPS

- A.** THE DRAINAGE TILE CURRENTLY CONNECTED TO THE EXISTING STORM SEWER SHALL BE CONNECTED TO THE PROPOSED STORM SEWER. ANY DRAINAGE TILE DAMAGED BY THE CONTRACTOR SHALL BE REPLACED BY THE CONTRACTOR TO A CONDITION EQUAL TO OR BETTER THAN ITS ORIGINAL CONDITION. ANYTHING REMOVED, REPLACED, AND/OR CONNECTED TO THE STORM SEWER SHALL BE NOTED ON THE AS-BUILT DRAWINGS AND SHALL BE INSPECTED BY THE INSPECTOR BEFORE THEY ARE COVERED.

- B.** ALL FIELD OR STORM DRAINS WHICH ARE ENCOUNTERED DURING CONSTRUCTION SHALL BE PROVIDED WITH UNOBSTRUCTED OUTLETS OR PLUGGED AS APPROVED AND DIRECTED BY THE CITY.



CITY OF
SIDNEY

MISCELLANEOUS STORM NOTES

REVISIONS:

DATE

APPROVED:
FEB., 2002

PAGE No.

600-11