



NOTES

PIPE SHALL HAVE A 8" MINIMUM COVER OF APPROVED AGGREGATE MATERIAL. APPROVED AGGREGATE MATERIAL SHALL BE CRUSHED STONE OR GRAVEL, ODOT 603 TYPE 3 (#67 OR #57) OR OTHER APPROVED EQUAL. PIPES SHALL BE BEDDED ON A 4" MINIMUM OF APPROVED AGGREGATE BASE.

AN INSPECTION VALVE/TEE, MANUFACTURED BY MAINLINE, IS TO BE INSTALLED IN THE RIGHT OF WAY. (SEE DETAIL 900-9). THE TEE SHALL BE INSTALLED INTO THE END OF THE EXISTING SERVICE LATERAL (WITH THE TEST PLUG INSERTED). IF THERE IS NO EXISTING SERVICE LATERAL AND ONE MUST BE INSTALLED, THEN THE TEST SHALL EXTEND FROM THE BUILDING TO THE SANITARY SEWER MAIN, UNLESS OTHERWISE APPROVED.

NOTES

- A. SEPTIC TANKS, WHEN ABANDONED, SHALL BE DEWATERED BY AN ACCEPTED SEPTAGE HAULER AND PROPERLY FILLED WITH GRANULAR MATERIAL. DRAIN HOLES SHALL BE BROKEN OUT ON THE BOTTOM AND SIDES OF THE TANK WHEN DIRECTED BY THE CITY.
- B. ROOF DOWNSPOUTS, EXTERIOR FOUNDATION DRAINS, AREAWAY DRAINS OR OTHER SURFACE RUNOFF OR GROUNDWATER SHALL NOT BE CONNECTED TO THE SANITARY SEWER MAIN. ALSO SEE MISC. NOTE B.
- C. ANY INDIVIDUAL OR FIRM INSTALLING SEWER LATERAL CONNECTIONS TO THE MAIN SHALL BE APPROVED BY THE CITY.
- D. BEFORE BEGINNING WORK, A SEWER TAP PERMIT MUST BE OBTAINED FROM UTILITY BILLING OFFICE AND APPLICABLE FEES MUST BE PAID.
- E. WHEN THE LATERAL MUST ENTER INTO A PAVED PORTION OF THE STREET OR ALLEY, A STREET OPENING PERMIT MUST BE OBTAINED FROM THE CITY ENGINEERING DEPARTMENT BEFORE BEGINNING WORK.
- F. WATER SERVICES SHALL BE A MINIMUM OF 10' MEASURED HORIZONTALLY FROM THE SEWER SERVICE AND SHALL BE A MINIMUM OF 18" ABOVE THE CROWN (WHENEVER POSSIBLE) OF THE SANITARY SEWER MAIN WHERE THE WATER SERVICE CROSSES THE SEWER MAIN.

PIPE

- A. THE PIPE MATERIAL SHALL BE PVC SDR 35 OR, SCHEDULE 40, UTILIZING PURPLE PRIMER, OR AN APPROVED EQUIVALENT.
- B. PIPE SIZES FOR LATERAL (NEW) SHALL BE 6" MINIMUM.
- C. THE BUILDING SEWER MAYBE 4" DIAMETER FOR SINGLE FAMILY RESIDENTIAL AND 6" DIAMETER FOR ALL OTHERS.

INSPECTION

- A. A TAP INSPECTION SHALL BE REQUIRED ON ALL NEW BUILDING CONNECTIONS AND ALSO ON THE REPLACEMENT OF EXISTING BUILDING CONNECTIONS.
- B. WHEN THE BUILDING SEWER IS READY FOR INSPECTION, THE CITY SHALL BE GIVEN 24 HOURS ADVANCE NOTICE. THE PIPE SHALL BE LEFT UNCOVERED UNTIL AN INSPECTION HAS BEEN MADE AND APPROVED.
- C. ALL NEW LATERALS SHALL BE INSTALLED WITH AN INSPECTION VALVE/TEE, MANUFACTURED BY MAINLINE, LOCATED AT THE PROPERTY LINE. ANY NEW BUILDING CONNECTION INSTALLED WITHOUT AN INSPECTION SHALL RESULT IN NO ISSUANCE OF A WATER METER FOR THE BUILDING. IF THIS OCCURS, THE ENTIRE LATERAL SHALL BE UNCOVERED SO THAT A PROPER INSPECTION CAN BE MADE.
- D. NO TAP FEE IS REQUIRED IF AN OLD BUILDING SEWER IS TO BE REUSED. AN INSPECTION WILL BE REQUIRED. THE ENGINEERING DEPT. SHALL INSPECT THE ENTIRE BUILDING CONNECTION FROM THE CLEANOUT TO THE PROPERTY LINE CONNECTION OR TO THE MAIN SEWER, WHICHEVER IS APPLICABLE.
- E. WHEN A SADDLE IS TO BE INSTALLED, THE INSPECTOR SHALL BE PRESENT WHILE THE SANITARY SEWER MAIN IS BEING CUT INTO. A SADDLE MAY BE USED WHERE A TEE OR WYE IS NOT PRESENT FOR LATERAL CONNECTION.

TESTING

- A. THE OUTSIDE PLUMBER SHALL BE RESPONSIBLE FOR THE TESTING FROM THE CONNECTION TO THE EXISTING SERVICE LATERAL TO THE CLEANOUT.
- B. ALL NEW BUILDING CONNECTIONS SHALL BE BY AIR WITH 4 PSI PRESSURE.

- C. THE SEWER TEST SHALL BE FROM THE BUILDING SEWER CLEANOUT TO THE PROPERTY LINE CONNECTION OR TO THE MAIN SEWER, WHICHEVER IS APPLICABLE.
- D. WHEN A SUBSTANTIAL AMOUNT OF AN EXISTING LATERAL IS REPLACED, THE NEW PORTION OF THE LATERAL SHALL REQUIRE A TEST UNLESS OTHERWISE APPROVED.

MISC.

- A. STREET EXCAVATION REQUIRES A STREET OPENING PERMIT.
- B. BASEMENT FLOOR DRAINS AND SUMP PUMPS, THAT CARRY GRAY WATER, SHALL BE CONNECTED TO THE SANITARY SEWER. FOUNDATION DRAINS AND ALL OTHER SUMP PUMPS, EXCEPT AS NOTED ABOVE, ARE TO BE CONNECTED TO THE STORM SEWER OR DISCHARGED ONTO THE GROUND.

PIPE LAYING

- A. THE OPEN ENDS OF ALL PIPES SHALL BE PLUGGED OR OTHERWISE CLOSED WITH A WATERTIGHT PLUG TO THE APPROVAL OF THE CITY BEFORE LEAVING THE WORK SITE FOR THE NIGHT.
- B. THE JOINING OF PIPE WITH CONCRETE SHALL NOT BE ACCEPTED.
- C. BEFORE MAKING A CONNECTION TO AN EXISTING SEWER OR SERVICE LATERAL, THE CONTRACTOR SHALL CHECK THE EXISTING PIPE BY UTILIZING A DYE TEST TO SEE THAT THE EXISTING PIPE IS CONNECTED TO THE SANITARY SEWER MAIN.
- D. IN THE CASE WHERE A 90° CORNER IS REQUIRED IN THE BUILDING CONNECTION LINE, TWO 45° BENDS SHALL BE USED IN LIEU OF A 90° BEND.
- E. THE BUILDING CONNECTION LINE SHALL BE LAID IN AS STRAIGHT A LINE, FROM THE BUILDING TO THE EXISTING LATERAL, AS POSSIBLE.
- F. ALL NEW CONSTRUCTION SHALL HAVE SANITARY LATERALS INSTALLED.
- G. MINIMUM SLOPE OF SANITARY LATERAL SHALL BE 1% GRADE (1/8" PER FOOT) MAXIMUM SLOPE (SEE 900-7).



BUILDING SEWER CONNECTION DETAIL

REVISIONS: 06-25-07 07-22-13	DATE APPROVED: FEB. 2002
PAGE No. 900-10	