



SERVICE TEES ARE PERMITTED IF

- A. SHOWN ON AN APPROVED SET OF CONSTRUCTION PLANS.
- B. 4" MINIMUM BRANCH AND SERVICE LINE WITH GATE VALVE
WITHIN 3' OF MAIN.

NOTE

- A. METER SHALL BE LOCATED INSIDE THE BUILDING.



CITY OF
SIDNEY

**4" AND LARGER WATER MAIN SERVICE CONNECTION
(DOMESTIC)**

REVISIONS:	DATE APPROVED: 06/03/2020
	PAGE No. 800-12