



NOTES

- A. ALL UNDERGROUND JOINTS MUST BE RESTRAINED.
- B. INSIDE PIPING SHALL BE D.I.P. CLASS 53 TO RIGID FLANGE, FROM RIGID FLANGE THROUGH METER VALVES AND BYPASS, TO BE D.I.P. CLASS 53, K-COPPER OR BRASS.
- C. MINIMUM 1-1/2" WATER METER.
- D. ALTERNATE DESIGN MAY BE SUBMITTED TO CITY FOR APPROVAL.
- E. COMBINATION SERVICE NOT PERMITTED INSIDE BUILDING IF THE DOMESTIC METER IS MORE THAN 75 FEET FROM THE PROPERTY/EASEMENT LINE.
- F. 6" FIRE LINE MAY HAVE A 1" DOMESTIC TAP AND 8" FIRE LINE MAY HAVE A 1-1/2" DOMESTIC TAP. ALL DOMESTIC TAPS MUST BE INSTALLED BEFORE THE SPRINKLER RISER.
- G. FIRE DEPARTMENT CONNECTIONS (TO INCLUDE 5" LOCKING STORZ CONNECTION WITH 30° DOWNWARD ANGLE) TO BE LOCATED ON THE OUTSIDE OF BUILDING AND SHALL BE APPROVED BY THE FIRE DEPARTMENT.
- H. UP TO 1" DOMESTIC TAPS CAN BE MADE ON FIRE LINES 6" OR LARGER AS THE TAP IS MADE PRIOR TO THE DETECTION CHECK AND METER.



CITY OF
SIDNEY

COMBINATION FIRE AND DOMESTIC IN BUILDING

REVISIONS: 03-13-23	DATE APPROVED: 06/03/2020
PAGE No. 800-14	