



NOTE:

A. ALL BACKFLOW PREVENTION ASSEMBLIES SHALL BE DELIVERED FOR INSTALLATION COMPLETELY ASSEMBLED BY THE ORIGINAL MANUFACTURER WITH ALL COMPONENTS AS APPROVED.

B. ADDITION OF BACKFLOW DEVICE ONTO EXISTING FIRE SUPPRESSION SYSTEMS WILL AFFECT ORIGINAL FLOW CALCULATIONS.

C. CLASS 53 DUCTILE IRON TO VALVE. ALL JOINTS RESTRAINED.



CITY OF  
SIDNEY

## REDUCED PRESSURE DETECTOR ASSEMBLY

|            |                              |
|------------|------------------------------|
| REVISIONS: | DATE APPROVED:<br>06/03/2020 |
|            | PAGE No.<br>800-15           |